



## TIPS FOR RESIDENTIAL HEATING OIL TANK OWNERS

Residential heating oil tanks are tanks that store fuel oil to provide space heating on premises where they are located. With proper tank management, spills and leaks can be avoided. Leaking tanks can contaminate public and private drinking water supplies, pollute soils, create the potential for fires and explosions, and subject tank owners to very expensive cleanup costs. A typical cleanup cost for spills and overfills from heating oil tanks ranges from \$10,000 to \$50,000 and is often not covered by typical homeowner's insurance policies.

### ***How can heating oil tanks be protected from spills and overfills?***

1. **ROUTINELY INSPECT THE EXTERIOR OF AN ABOVEGROUND TANK AND ALL ATTACHED EQUIPMENT.** Many times, leaks can easily be detected and corrected before extensive environmental damage occurs. Tanks and equipment should be inspected for uniform corrosion, pitting, holes, leaking pipes, loose joints and loose fittings. Be aware that most corrosion failures occur from water sitting at the bottom of the tank. Tanks rust from the inside out. **A freshly painted tank doesn't mean that it is structurally sound!**

Tanks can collapse when the tank legs rust or when the soil underneath settles due to the freezing and thawing cycle. To prevent collapses, tanks and equipment should be frequently inspected for structural soundness, such as weak or unsteady support legs. Tanks should be installed on a concrete pad and be secured with floor flanges and concrete anchors. Never place an aboveground tank directly on the soil. **Remember**, a 275-gallon tank full of heating oil weighs over one ton. Tanks need to be installed in a secure area, away from vehicular traffic, and be protected from high winds and any potential falling objects such as tree limbs, snow, ice, etc., that could damage the tank or break the attached equipment.

2. **INSTALL SPILL AND OVERFILL PREVENTION DEVICES.** Spills and overfills occur when product is delivered to the tank. There are simple and generally inexpensive devices that can be installed on tanks to prevent this from occurring. The product distributor can advise the tank owner about available devices.
3. **ENSURE THE TANK ADDRESS IS CLEARLY VISIBLE AND THE FILL LINE IS CLEARLY MARKED.** This is extremely important for multi-family dwellings and in areas where dwellings are located close together. Many spills and overfills have resulted from deliveries made to the wrong tank.
4. **CONSIDER A SECONDARY CONTAINMENT STRUCTURE.** If a release from the tank does occur, the easiest way to limit the liability is to capture and contain the entire release before it enters the environment. Double-walled underground tanks, diked aboveground tanks, and retrofit structures for existing aboveground tanks are readily available. A product distributor can advise tank owners on various options.

### ***Is it important to remove the fill pipe when a tank is removed?***

Yes. There are numerous documented cases of heating oil being delivered through fill pipes for basement tanks that no longer exist. Some simple steps to avoid this costly mistake include: 1) Remove the fill line after the removal of the tank; 2) If the fill line cannot be removed, then permanently seal both ends of the fill pipe; 3) Contact the oil delivery company and inform them that the tank has been removed and that under no circumstances should a delivery be made to the tank.

#### **Self-Inspection Checklist for Basement and Backyard Aboveground Home Heating Oil Tanks (ASTs)**

*If the answer is "YES" to any of the following questions, call an oil burner technician for a more detailed inspection and corrective measures.*

- Are the tank legs unstable or on a precarious foundation?
- Is the tank vent clogged or restricted because of ice, snow or insect nests? (Screened vents can prevent insect nest problems.)
- Are there any signs of rust, weeps, wet spots or excessive dents on the tank's surface?
- Is the overfill whistle silent when the tank is being filled? (Ask your delivery person.)
- Are there any drips or signs of leakage around the filter or valves?
- Are there signs of spills around the fill pipe or the vent pipe?
- Do the oil lines between the tank and the furnace run either under concrete or aboveground without being encased in protective tubing?
- Is the fuel-level gauge cracked, stuck or frozen...or are there signs of oil around it?
- Is there danger of snow or ice falling on the tank?
- Are you using more oil than normal?

#### **Self-Inspection Checklist for Home Heating Oil Underground Storage Tanks (USTs)**

*If the answer is "YES" to any of the following questions, call an oil burner technician for a more detailed inspection and corrective measures.*

- Are you using more fuel than normal?
- Is the tank vent clogged or restricted because of ice, snow or insect nests? (Screened vents can prevent insect nest problems.)
- Is the tank taking on water - a rise in water level greater than 1/2" for an 8- to 12-hour period? (An oil-burner technician can check for water or provide the owner with water-finding paste to check themselves.)
- Is the overfill whistle silent when the tank is being filled? (Ask a delivery person.)

**Are there indicators that a residential heating oil tank might be leaking or product has been spilled?**

Yes. There are many indicators, including:

- Soil is saturated with heating oil;
- Soil or other surface material around the fill pipe is stained;
- Product vapors are in the soils or in the basement area;
- Fuel is seeping into a basement, stream, underground utility, etc.;
- Drinking water supplies are contaminated;
- Fuel consumption has suddenly increased;
- Furnace is operating erratically; and
- Neighbors are complaining of fuel oil odors.

**What should be done if a residential heating oil tank leaks?**

- √ Identify the source of the release. If the source cannot be located, contact a professional to test the tank and/or piping system to locate the area of the release.
- √ Stop or contain the release. Absorbent material like cat litter can help stop the release from spreading. Call a professional, such as the product distributor, to remove as much product from the tank as necessary to prevent further release.
- √ Begin cleanup and contact the Department of Environmental Protection (DEP). Contact professionals to help determine the extent of contamination, prepare a cleanup plan and clean up the site. The cost and quality of work can vary greatly. For information on how to hire contractors, refer to the DEP Storage Tank Cleanup Program's Fact Sheet 1610, "Leaking Underground Storage Tanks: Controlling Cleanup Costs." Owners may want to first notify their private insurance company before hiring a contractor to see if any cleanup costs are covered. Furthermore, some insurance companies want to approve a contractor first as part of their policies. Remember, it is the responsibility of the tank/property owner to initiate and complete all necessary corrective action measures which includes formal notification of the release to the appropriate DEP regional office. For more information on DEP's cleanup standards and/or to report a release, please contact the appropriate DEP regional office listed below.
- √ Keep detailed and accurate records. It is very important to keep records of cleanup action plans and actions taken.
- √ Help may be available. DEP has a reimbursement program for tank owners who have underground storage tanks with a capacity of 3,000 gallons or less used for storing heating oil for consumption on the premises where stored to assist with costs of taking corrective action in response to a release. The release must have occurred on or after Jan. 30, 1998. For more information, including full details, instructions and the application form, visit [www.dep.state.pa.us](http://www.dep.state.pa.us), keyword: Storage Tank Cleanup Program.

**Regional DEP Offices:**

**Northwest Region**

230 Chestnut St.  
Meadville, PA 16335-3481  
814-332-6648

**Counties:** *Butler, Clarion, Crawford, Elk, Erie, Forest, Jefferson, Lawrence, McKean, Mercer, Venango and Warren*

**North-central Region**

208 West 3rd St., Suite 101  
Williamsport, PA 17701-6448  
570-327-0500

**Counties:** *Bradford, Cameron, Centre, Clearfield, Clinton, Columbia, Lycoming, Montour, Northumberland, Potter, Snyder, Sullivan, Tioga and Union*

**Northeast Region**

2 Public Square  
Wilkes-Barre, PA 18701-1915  
570-820-4902

**Counties:** *Carbon, Lackawanna, Lehigh, Luzerne, Monroe, Northampton, Pike, Schuylkill, Susquehanna, Wayne and Wyoming*

**Southwest Region**

400 Waterfront Drive  
Pittsburgh, PA 15222-4745  
412-442-4091

**Counties:** *Allegheny, Armstrong, Beaver, Cambria, Fayette, Greene, Indiana, Somerset, Washington and Westmoreland*

**South-central Region**

909 Elmerton Ave.  
Harrisburg, PA 17110-8200  
717-705-4705

**Counties:** *Adams, Bedford, Berks, Blair, Cumberland, Dauphin, Franklin, Fulton, Huntingdon, Juniata, Lancaster, Lebanon, Mifflin, Perry and York*

**Southeast Region**

2 East Main St.  
Norristown, PA 19401-4915  
484-250-5960

**Counties:** *Bucks, Chester, Delaware, Montgomery and Philadelphia*

**Central Office**

**Bureau of Environmental Cleanup and Brownfields**

**Division of Storage Tanks**

P.O. Box 8762  
Harrisburg, PA 17105-8762  
717-772-5599  
800-42-TANKS (in PA only)

For more information, visit [www.dep.state.pa.us](http://www.dep.state.pa.us), keyword: Storage Tanks.